

# T E S T C E R T I F I C A T E

ST-23-12-11-02

**Product:** Laminate Flooring "YILDIZ ENTEGRE AQUA LAMINATED PARQUET"

**Producer:** Yıldız Entegre Ağaç Sanayi ve Tic.A.Ş.  
Arslanbey O.S.B. Mah. 1. Cadde No:13  
41285 Kartepe-Kocaeli  
Turkey

**Order:** Determination of Laminate Flooring Topical Moisture Resistance according to NALFA-Method after 72 hours water load


**Test report:** 2723602/1

**Test results:**


*For extended 72 hours water load:*

Parameter		Wet Swell	Re-dry Swell / Rating	Requirements according NALFA (24 hours)
Final Thickness Swell [mm]	Position 1	0,52	0,39	Not applicable
	Position 2-4	0,31	<b>0,15</b>	<b>Fulfilled</b>
Qualitative Rating Specimen 1/2		4/3	<b>2/1</b>	
Water Leakage		Not detected		Not applicable

Dresden, 11/12/2023



Head of laboratory

Engineer in charge